

SOUTHERN NEVADA HEALTH DISTRICT
280 SOUTH DECATUR BLVD • PO BOX 3902 • LAS VEGAS, NV • 89127 • 702-759-0660 (DIRECT)• 702-759-1000(24 HOURS)
APPLICATION TO CONSTRUCT
INDIVIDUAL SEWAGE DISPOSAL SYSTEM (ISDS)

SYSTEM INFORMATION	
Permit No.	ON0
Property Owner	
Type of Facility	
SFR	
Perc Rate	Lot Size
15	0
Minimum ISDS Required	
Septic Tank	Absorption
1,500	86

Fixtures	No.
Shower	1
Water Closet	4
Bath Tub	2
Double Lav	1
Single Lav	3
Kitchen Sink	1
Wet Bar	
Clothes Washer	1
Laundry Tab	1
Veggie Sink	1
Bidet	
Bar Sink	
Floor Drains	
Drinking Fountain	
Floor Sink	
Commercial Sink	
Trailer park	
Urinals	
Grease/Oil Interceptor	
Sand/Water Interceptor	
Commercial Water Closet	
Total Fixture Units	25

FACILITY INFORMATION			
Jurisdiction Code	Emp #		
0 - Clark County	E		
Address			
City	State	Zip code	Water Supply Type
Las Vegas	NV		03 - Public Water System

OWNER INFORMATION			
Area	Telephone	Ext	
Owner/Contact			APN
Street #	Street Name	City	State Zip
		Las Vegas	NV

ALL APPLICABLE REQUIREMENTS ARE INCLUDED IN THE CURRENT EDITION OF THE "SOUTHERN NEVADA DISTRICT BOARD OF HEALTH REGULATIONS GOVERNING ISDS AND LIQUID WASTE MANAGEMENT".

NOTE: NO PAVING OR VEHICULAR TRAFFIC ALLOWED OVER INDIVIDUAL SEWAGE DISPOSAL SYSTEMS (ISDS) OR TREES WITHIN TEN FEET (10') OF ISDS. THIS INSTALLATION IS APPROVED ONLY UNTIL SEWER IS AVAILABLE.

COMMENTS:

Sewer is not available per GIS. A 1,500 gallon septic tank and a 816 sqft leach field consisting of 68 Quick4 (3'x4') chambers will be installed. Soil borings indicate that caliche was encountered at shallow depths (~2-4'). Remove any caliche that is encountered when excavating the leach field and dig a test hole for inspection by SNHD to confirm that no caliche was encountered. The depth of the test hole must be five (5) feet below the bottom of the leach field excavation, and it should be in the immediate vicinity of the leach field.

Permit to construct expires one year from: 01/15/2021

Dan Isler

Application Approved by _____ Applicant _____



DATE:		SCALE 1/16"=1'-0"
CITY:		BY: DRAWN
ADDRESS:		
OWNER:		
SHEET: 2		OF 6

***** Site plan must match plans submitted to Clark County Building Dept. *****



SAMPLE