



# Clark County Building Department

## FIELD INSPECTION GUIDELINE

<b>Division:</b>	<b>Inspections</b>	<b>Policy &amp; Procedure:</b>	<b>FIG-M-003</b>
<b>Subject:</b>	<b>Review &amp; Performance Test / Certification</b>	<b>Effective Date:</b>	11/16/1999
<b>Code:</b>	<b>2018 UMC Amendment Section 511.2.2.1.1</b>	<b>Revised Date:</b>	<b>11/01/21</b>
<b>Proposed:</b>	<b>Matthew Brewer</b>	<b>Approved:</b>	<b>Jim Gerren</b>

### **Interpretation:**

The above amendment section cites the requirements for performance tests on exhaust equipment used in conjunction with commercial heat-processing equipment. This amendment of the Clark County Mechanical Code, Section 511.2.2.1.1 provides the installer the option of performing the test using an approved third-party testing agency or, at the discretion of the Building Official, using a Building Department representative that shall witness the test by an approved third-party testing agency.

### **Field Application:**

When performance testing is verified by a third-party (QAA), a completed copy of the report shall be uploaded under the BDIA number by the QAA agency. The submittal of the report will create a Type I or Type II inspection scheduled in the name of the mechanical inspector assigned to the area. A copy of the submitted form must also be kept on site, to be used for inspection purposes.