



Clark County Building Department

4701 West Russell Road • Las Vegas NV 89118

(702) 455-3000 • Fax (702) 221-0630

Division:	Building Division – Plan Review	Policy & Procedure:	BD-PP-241
Subject:	Emergency Radio Responder Coverage System	Effective Date:	05/04/2024
Code:	N/A	Revised Date:	N/A

A. POLICY:

To provide direction on the scope of review or the requirements for separate electrical permits associated with Emergency Radio Responder Coverage Systems.

B. PROCEDURE:

1. Building Plans Examination will review only the 120V (or as required) electrical power supply to the unit per the National Electrical Code.

Building Department will issue, if necessary, an electrical permit for the installation of the power supply and/or conduit.

If there is no power supply to review, the plans examiner will verify the scope of work in Accela shows “ERRCS conduit only”.

Building Plans examiner will select the box for third-party inspection, Item Y, and mark the workflow as completed.

2. Clark County Fire Prevention will review, based on the IFC as amended, the battery backup systems, antenna locations, materials being used and their ratings, the fire-rating of the enclosure and conduit or cables as well as the trouble signal for power failure monitoring.

Prepared By: Terry Kozlowski

Date Prepared: 03/11/2024

Revision History:

Title	Revision/Approved Date	Effective Date
Emergency Responder Radio Coverage System	05/04/2024	05/04/2024

Reviewed by:

Jake Mizrahi
Jake Mizrahi
Engineering Manager

Terry Kozlowski
Terry Kozlowski
Manager of Plans Exam.

Shannon McEwen
Shannon McEwen
Manager Building Permits

Matthew Brewer
Matthew Brewer
Manager of Inspections

Zach Gharibian
Zach Gharibian
ACET Manager

James Oleniczak
James Oleniczak
Senior Management Analyst

Theresa Atimalala
Theresa Atimalala
Senior Management Analyst

Werner Hellmer
Werner Hellmer, P.E., CBO
Deputy Director

Scott Telford
Scott Telford, P.E., CBO
Deputy Director

Approved by:

James Gerren
James Gerren, P.E. C.B.O
Director & Building Official