

FINAL ACTION REPORT

for

PART 70 PERMIT

Switch, Ltd.

Source Number 16304

Application Date: September 5, 2024
Type of Action: Significant Revision to Title V Operating Permit
Public Notice: *Review-Journal*, March 25, 2025
Public Review: March 25, 2025 to April 23, 2025
EPA Review: March 25, 2025 to May 8, 2025

Issuance date: July 1, 2021
Expiration date: June 30 2026
Revision date: May 15, 2025

Copies of comments received and responses to all comments are part of this final action report. All responders shall receive an electronic copy of this report, the final Part 70 Operating Permit, and the final Technical Support Document.

After completion of the public comment and EPA review periods, DAQ revised the draft Part 70 OP to include following changes:

1. Included applicable requirements of AQR 121 “Reasonably Available Control Technology Determinations for Specific Major Stationary Sources in the 2015 8-Hour Ozone NAAQS Moderate Nonattainment Area HA 212”. AQR 121 was adopted on February 4, 2025, with an effective date of February 18, 2025. For existing permit conditions that satisfy the requirements of AQR 121, references to the applicable AQR 121 requirements have been included.
2. A NO_x emission concentration limit for emergency generators emission units. The limit was included for compliance demonstration purposes associated with an existing emission monitoring requirement for emergency generators. A full explanation of the revision and accompanying calculation methodology submitted by the permittee are included in the Technical Support Document.

Comments Received from Public:

None.

Comments Received from EPA:

None.

Attachments

None.