

TO WHOM IT MAY CONCERN:

This is to advise you that the 2012 Clark County Fire Code, Section 308.1.4, "Open-flame cooking devices", states the following:

Charcoal burners and other open-flame cooking devices, including electric barbecues that produce open flames, shall not be located on combustible balconies or within 10 feet (3048 mm) of combustible construction.

Exception: One- and two-family dwellings

This Department recommends the following safeguards for outdoor cooking safety at your complex by providing water for extinguishment (garden hose) in the event of a fire or a spill of hot coals and using a metal container specifically for the disposal of the used coals.

It is the responsibility of the property owner/manager and/or association to notify all tenants of this requirement. A copy of this letter signed by each tenant must be kept on file **at the complex** for Fire Prevention review.

Should you need further clarification of the above, please contact Fire Prevention at:
(702) 455-7316.

Tenant's signature and date