



CLARK COUNTY FIRE DEPARTMENT - FIRE PREVENTION BUREAU

4701 W Russell Rd, Las Vegas, NV 89118 • (702) 455-7316

Website: [Fire Department \(clarkcountynv.gov\)](http://FireDepartment(clarkcountynv.gov))

Email: FPPCQ@clarkcountynv.gov

Permit Submittal Guideline

REPAIR GARAGE: PERMIT BY INSPECTOR

Permit Use:

This guide is to assist in the permitting process for annual repair garage operations..

APPLICABLE CODES:

The following codes and standard apply to this permit:

- Permit is required for repair garages and auto body repair shops per section 105.6.47 of the Clark County 2024 International Fire Code (IFC) Amendments. All repair garage work shall comply with the requirements of Chapter 23 of the International Fire Code

Link to CCFC: See the amendments to codes using the link below:

[Chapter 13.04 THE FIRE CODE OF CLARK COUNTY.pdf](#)

SUBMITTAL REQUIREMENT CHECKLIST:

No items are required to be submitted as part of this permit. Permit conditions shall be field verified to meet the requirements below.

PERMIT BY INSPECTION ELIGIBILITY: All repair garages shall be issued as a permit by inspector.

Requirements for Repair garages:

1. Waste oil, motor oil and other Class IIIB liquids shall be stored in approved tanks and containers, which are allowed to be stored and dispensed from inside repair garages.
2. Sources of ignition shall not be located within 18 inches of the floor.
3. Smoking shall not be allowed in repair garages except in approved locations.
 - a. No Smoking signs posted in repair garage.
4. Fire extinguishers for repair garages are required with a minimum rating of 2A10BC. The distance of travel to reach an extinguisher in a repair garage shall not exceed 75FT in travel distance. A 2A20BC fire extinguisher shall be provided in repair garages with welding or hot works operations. Shall be tagged and serviced annually.
5. Flammable and combustible liquids stored in approved tanks and containers.
 - a. Separate operational permit required for flammable and combustible liquid storage based upon thresholds noted in the fire code.
6. Oily waste materials such as shop rags contained within approved metal containers with self-closing lids
7. All fire and life safety systems serviced, tagged, and fully operational.
8. Other permits may be required based on operations.

PERMIT DURATION:

All temporary operational use permits are only valid for the duration of the event and only up to a maximum of 180 days. If any changes are made to the arrangement, a revision or new permit will need to be applied for. Annual operational permits are valid for a period of up to 365 days.

To apply for your permit please visit your customer ACA account and apply for either an annual or temporary permit, then select Repair Garage from the drop-down menu. [Accela Citizen Access](#)