



Clark County Fire Department

FIRE PREVENTION BUREAU

4701 W. Russell Road • Las Vegas, NV 89118

John Steinbeck, Fire Chief

Kelly Blackmon, Sr. Deputy Fire Chief/Fire Marshal

Danny Horvat, Assistant Fire Chief • Wayne Dailey, Assistant Fire Chief



PERMIT GUIDE PERMIT BY INSPECTION DISPLAYED VEHICLES IN INDOOR ASSEMBLY SPACES

This guide is to assist in the permitting process for the display of liquid or gaseous fueled vehicles, boats, or other motorcraft in indoor assembly areas. The permit is to verify compliance with section 314.4 of the IFC. The number of displayed vehicles is not limited. Electric (battery) vehicles do not require a permit. The permit is for the display of vehicles and does not address operation of vehicles within occupied assembly spaces.

APPLICABLE CODES:

The following codes apply to this permit:

- *International Fire Code*, 2018 edition (IFC)
- *Clark County Fire Code Amendments*, 2018 edition (CCFC)

Link to CCFC: See the amendments to codes and standards using the link below:

https://cms8.revize.com/revize/clarknv/Building%20&%20Fire%20Prevention/Codes/ClarkCounty_FireCodeAmendments2018.pdf?t=1598331770575&t=1598331770575

SUBMITTAL REQUIREMENT CHECKLIST:

The listed requirements in this guide are not intended to be all inclusive, nor do they entail a limit to the extent of the information, etc. Not all items may apply to your event.

SUPPORTING DOCUMENTS CHECK LIST:

A plan (diagram) showing the location(s) of the vehicle must be available for Inspector review. It is to be drawn to an architectural scale or with detailed dimensions. Printed copy or an electronic display (i.e., a tablet or I-Pad) must be immediately available to the Inspector. The plan is to state that:

- Batteries are disconnected, or the engine starting system is made inoperable, except where the fire code official required that the batteries remain connected to maintain safety features
- Fuel in fuel tanks do not exceed one-quarter tank or five (5) gallons (19 liters) whichever is least
- Fuel tank and fill openings are closed and sealed to prevent tampering
- Vehicles, aircraft, boats or motorcraft are not fueled or defueled within the building
- Vehicles are greater than 20 feet away from any required exit
- Vehicles will not be driven or moved through occupied places of assembly

The Inspector will verify compliance with the plan, a 36-inch clear space around the vehicle and that there are no leaks of fuel, lubricants, coolants etc.

BOARD OF COUNTY COMMISSIONERS

JAMES B. GIBSON, Chair • JUSTIN JONES, Vice Chair

MICHAEL NAFT • ROSS MILLER • WILLIAM McCURDY II • TICK SEGERBLOM • MARILYN KIRKPATRICK
YOLANDA T. KING, County Manager

PERMIT DURATION:

Displayed vehicle permits are valid for 1 year and renewed. A new permit by inspector is need if the original conditions are modified.

HOW TO SUBMIT:

Supporting documents are to be submitted electronically. Files should be uploaded via the Clark County Citizen Access Portal:

<https://CreatOurOwnHyperlinkHere>

INSPECTION OPTIONS/INSPECTION SCHEDULING:

https://www.clarkcountynv.gov/government/departments/building_fire_prevention/inspection/schedule_an_inspection.php