



# Clark County Department of Building & Fire Prevention

4701 West Russell Road, Las Vegas, NV 89118 ~ (702) 455-3000

## Duct/Area Detector Test Data

Jerome A. Stueve, P.E., Director

Samuel D. Palmer P.E., Assistant Director • James Gerren P.E., Assistant Director • Girard W. Page, Fire Marshal

DATE: \_\_\_\_\_

CONTRACTOR NAME: \_\_\_\_\_

MECHANICAL PERMIT: \_\_\_\_\_

JOB NAME & ADDRESS: \_\_\_\_\_

TESTING EQUIPMENT TYPE: \_\_\_\_\_

Devices upon detection of smoke shall automatically shutoff air-moving  
Equipment by interrupting the power source.

(Check one)

DUCT DETECTORS

AREA DETECTORS

NUMBER OF DEVICES AT THIS LOCATION: \_\_\_\_\_

MANUFACTURER'S NAME & MODEL NUMBER: \_\_\_\_\_

MANUFACTURER'S AIRFLOW REQUIREMENTS: (When duct detectors are used.)

(fpm min.) \_\_\_\_\_ (fpm max.) \_\_\_\_\_

ACTUAL AIRFLOW AS MEASURED AT DEVICE: \_\_\_\_\_

EQUIPMENT AIRFLOW OUTPUT: \_\_\_\_\_  
(CFM or tonnage as shown on rating plate)

EQUIPMENT SHUT OFF ACCOMPLISHED WHEN DEVICE PUT INTO ALARM:

(Check one)  YES:  NO:

TIME REQUIRED FOR SHUTOFF ONCE DEVICE SET IN ALARM:

SECONDS: \_\_\_\_\_ (15 seconds max permitted time)

PERSON PERFORMING TEST: \_\_\_\_\_

TITLE & AFFILIATION: \_\_\_\_\_

Save Form

Reset Form

Print Form