



Clark County Department of Building & Fire Prevention

4701 West Russell Road • Las Vegas NV 89118

(702) 455-3000 • Fax (702) 221-0630

Division:	Building & Fire Prevention	Policy & Procedure:	BD-CI-205
Subject:	Roof Live Load for Primary Roof Members Exposed to a Work Floor	Effective Date:	03/17/2020
Code:	2018 IBC Table 1607.1 #26	Revised Date:	03/17/2020

A. CODE SECTION:

OCCUPANCY OR USE	UNIFORM (psf)	CONCENTRATED (pounds)
26. Roofs Single panel point of lower chord of roof trusses or any point along primary structural members supporting roofs over manufacturing, storage warehouses, and repair garages.		2000

B. CODE INTERPRETATION:

All trusses are required to meet the 2,000 lb. concentrated roof live load requirement regardless of spacing. Premanufactured I-joists (joists with continuous plywood sheathing as the web) spaced at 24" on center or less would not have to meet this requirement, as long as, the engineer can demonstrate that one I-joist failing would not result in a roof collapse in that area.

Prepared By: Scott Telford, P.E.

Date Prepared: 03/17/2020

Revision History:

Title	Revision/Approved Date	Effective Date
Roof Live Load for Primary Roof Members Exposed to a Work Floor		03/17/2020

Reviewed by:

Werner Hellmer
Werner Hellmer, P.E.
Engineering Manager

David Logsdon
David Logsdon
Manage of Plans Exam.

Zach Gharibian
Zach Gharibian
ACET Manager

Matthew Brewer
Matthew Brewer
Manager of Inspections

Danny Horvat
Danny Horvat
Assistant Fire Chief

Wayne Dailey
Wayne Dailey
Assistant Fire Chief

Girard Page
Girard Page
Fire Marshall

Amara Vigil
Amara Vigil
Senior Management Analyst

Ofelia Monje
Ofelia Monje
Senior Management Analyst

Samuel D. Palmer
Samuel D. Palmer, P.E. C.B.O
Assistant Director

James Gerren
James Gerren, P.E. C.B.O
Assistant Director

Jerome A. Stueve
Jerome A. Stueve, P.E.
Director/Building & Fire Official

Roof Live Load for Primary Roof Members
Exposed to a Work Floor